

Fusion Neutronics Meeting 2025: ITER and beyond,  
Madrid 7<sup>th</sup> – 10<sup>th</sup> April 2025



# Shutdown Dose Rate Assessments due to Water Contamination in EU-DEMO Primary Heat Transfer Systems

N. Terranova, S. Breidokaité, A. Colangeli, F. Dacquait, D. Flammini, N. Fonnesu, T. Kaliatka, M. Lungaroni, F. Moro, S. Noce, A. Previti, G. Stankunas, R. Villari



This work has been carried out within the framework of the EUROfusion Consortium, funded by the European Union via the Euratom Research and Training Programme (Grant Agreement No 101052200 — EUROfusion). Views and opinions expressed are however those of the author(s) only and do not necessarily reflect those of the European Union or the European Commission. Neither the European Union nor the European Commission can be held responsible for them.


# Background



*“Since the beginning of the development of water-cooled nuclear power reactors, it has been known that the **materials in contact with water release some of their corrosion products into the water.**”*


*“The growth of **gamma radiation fields** around the surfaces of out-core materials was noted from the beginning of the development of nuclear power reactors.”* (From IAEA-TECDOC-1672)

From IAEA TEC-DOC 1672



Courtesy F. Dacquit

Principle of contamination transfer in a nuclear cooling system



System walls exposed to water release corrosion products into the coolant. They are transported into the vessel where they can deposit and become **activated**. In-core or in-vessel activated corrosion products are released into the coolant. They could be **incorporated in the ex-vessel surfaces and generate radiation fields**.

# Background (cont'd)




## Water Contamination: The Activated Corrosion Products problem in Water Cooling Systems

The ACP determination is fundamental in safety analyses and source term quantification in Fusion Power Plants for the following reasons:

- **Occupational dose.** Important gamma emitting radionuclides are contained in form of deposit, inner oxide, particle in suspension, and ions in solution.
- **Maintenance plan definition** (e.g. inspectability, filter and resins replacement frequency, etc.)
- **Machine availability**
- **Waste management**
- **Accident consequence estimation** (some ACP are in form of mobilizable source terms)
- **Component qualification.**

Collective dose for operation and maintenance of PWRs




# Table of Contents



- Scope of the activity and expected results
- Methodology proposed: a calculation scheme for SDDR due to water contamination
- Computational tools:
  - OSCAR-Fusion V1.4a
  - pipe\_source patch for MCNP 6.2
- Preliminary Results on EU-DEMO and current issues
- Outlook and Conclusions

# Scope of the activity and expected results



## Main goal:

To provide **dose rate maps** around the most important components of EU-DEMO Primary Heat Transfer System (e.g. Divertor, Breeding Blanket).

Heat Exchangers, Steam Generators, Cold and Hot legs, Pumps etc.  
(requiring preventive and scheduled maintenance)

Time considered:

At the end of each maintenance shut-down + relevant cooling times.


# Methodology



The methodology relies on a 3 main steps scheme:


1. Activation reaction rate calculation
2. OSCAR-Fusion modelling and calculation for ACP estimation
3. Gamma transport with MCNP 6.2 + pipe\_source patch

Activation Reaction Rate calculation, generally calculated using Monte Carlo means.




## OSCAR-Fusion:

- Input: RR+TH+Chem+Geo etc.
- Output: ACP inventories per component



Gamma Transport for SDDR maps, e.g. MCNP



# Methodology (cont'd)



- **Integral reaction rates** must be calculated for OSCAR-Fusion for activation reactions.
- They should be **representative of the RR in the water cooling pipes** under neutron flux.
- **Several methodologies** are used in the fusion community (single RR tallies in MCNP, two steps i.e.  $\sum \phi \times \sigma$ , production rates from FISPACT, etc.)

Integral RR

- RR are included in the **NUCLEO database** of OSCAR-Fusion
- OSCAR-Fusion solves the **Bateman equation** together with the mass balance equation for material transport and component contamination
- Requires **thermal-hydraulics, chemistry, geometrical, operational, and technological modelling** of the system

ACP



- ACP are processed with **ActiGamma** to have gamma lines and intensities.
- The pipe\_source patch is used to define “**tagged pipes**”
- **Gamma emitting surfaces and volumes** are defined according to the surface activity provided by OSCAR-Fusion
- The gamma transport is executed by MCNP.



# Computational Tools



- ✓ **OSCAR-Fusion V1.4a: tool for Simulating Contamination in Reactor**, derived from OSCAR -> originally developed for **PWRs** by **CEA** in collaboration with EDF and Framatome. Validation based the French nuclear fleet (~430 EMECC campaigns)
- ✓ **Pipe\_source patch for MCNP 6.2:** developed by **UKAEA**. Sampling from either cylindrical, right-angled-parallelepipeds (cubes) or curved corners.







# Preliminary Results




- Parametric results have been produced for the DIV-PHTS of EU-DEMO at the end of each Maintenance shut-down.
- The effect of the design choices, especially on the CVCS has been investigated.
- Important dose rates levels have been calculated, but results are still preliminary.





## Main Issues:

- A **three-steps calculation scheme** is quite **complicated and error-prone**. Python scripting has been adopted to automatize the whole process.
- **Error propagation is an issue**. Biases from nuclear data, corrosion laws etc. combine together and propagates in a long calculation chain.
- **MCNP+OSCAR+MCNP** is a **CPU time-consuming** calculation chain. **Far away from what is done in nuclear industry** (e.g. **NARMER** a point-kernel+build-up radiation protection code used in France, derived from MERCURE and developed by CEA)
- OSCAR and MCNP **modelling is extremely time consuming**. A feature that is not suitable to an evolving design, which might require parametric calculations.



# Outlook and Conclusions



- A three-steps calculation scheme based on **MCNP** and **OSCAR-Fusion** has been put in place to **estimate shut-down dose rates** around the most important components of the PHTS of EU-DEMO.
- Preliminary **results are produced on the DIV-PHTS**.
- Developments and calculations on the BB-PHTS are ongoing (ACP results are produced).
- Intrinsic water activation results can also be used (e.g., from ACABLoop, results provided by M. Garcia)
- The issues linked to the **complexity of the methodology** and error propagation have been highlighted.
- Future work will examine the possibility to use simplified MCNP models or point-kernel codes.

# Acknowledgements



This work has been carried out within the framework of the EUROfusion Consortium, funded by the European Union via the Euratom Research and Training Programme (Grant Agreement No 101052200 — EUROfusion). Views and opinions expressed are however those of the author(s) only and do not necessarily reflect those of the European Union or the European Commission. Neither the European Union nor the European Commission can be held responsible for them.

Special thanks to:

**G. Mariano** from ITER Organization for his full support and useful discussions.

**T. Berry** and **T. Eade** from UKAEA for the pipe source patch delivery and support documentation.

**FNM Organizing Committee** here in Madrid.



# Thank you for your attention

[nicholas.terranova@enea.it](mailto:nicholas.terranova@enea.it)

[simone.noce@enea.it](mailto:simone.noce@enea.it)